

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J		PAGE OF PAGES 1 3	
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 10-Aug-2006		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY NAVAL SURFACE WARFARE CENTER, CARDEROCK DOROTHY JONES, CODE 3352 DOROTHY.JONES1@NAVY.MIL 5001 SOUTH BROAD STREET PHILADELPHIA PA 19112-1403		CODE N65540		7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. N65540-06-R-0020	
				X		9B. DATED (SEE ITEM 11) 28-Jun-2006	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.							
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
The closing date is hereby extended until 4:30 PM local time 28 August 2006.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)		14-Aug-2006	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

1. ANSWERS TO OFFEROR'S QUESTIONS

Question - Page 3 of 51 – YORK needs details on specific piece parts to be provided for the relief valve and bursting disk installations on the air conditioning plant and refrigerant receiver. The information needs to include manufacturer's part numbers for all hardware to be provided. York assumes that the relief valve and bursting disk installations will be performed in the field by non-York personnel. York requires this information to prepare the quotation.

Answer – Remove the requirement for York to provide relief valve and bursting disks from the requirements.

Question - Page 3 of 51 – York assumes quantities as follows for Item 0001: Motor controller quantity one, compressor motor quantity one, CWCV quantity one, PPO quantity one, refrigerant receiver quantity one, oil drain tanks quantity 3, relief valve and bursting disks quantity one for a/c plant and one for receiver, resilient mounts quantity 8, snubbers quantity 16, snubber sockets quantity 16, HFC236fa refrigerant quantity 1,200 lbs, POE oil (York J oil) quantity 15 gallons. York assumes that the fasteners required for installing the resilient mounts, snubbers and snubber sockets will be supplied by others.

Answer – Concur with York assumption of quantities required, one set necessary for 300 ton HFC-236fa AC.

Question - Page 6 of 51 – This section states that the "target flow meter" should be shipped separately. There is no target flow meter included in the scope of supply (Item 0001 on page 3 of 51) and York assumes none is required.

Answer – The requirements for the target flow meter is deleted in its entirety.

Question - Page 25 of 51 – CDRL A001 – Product Drawings and Associated Lists. York assumes that this CDRL will be removed from the contract requirements.

Answer – CDRL A001 is deleted in its entirety.

Question - Page 33 of 51 – CDRL B006 – York assumes that this CDRL will be removed from the contract requirements.

Answer – CDRL B006 is deleted in its entirety.

Question - Page 34 of 51 – CDRL B007 – York assumes that this CDRL will be removed from the contract requirements.

Answer – CDRL B007 is deleted in its entirety.

Question - Page 35 of 51 – CDRL B008 – York assumes that this CDRL will be removed from the contract requirements.

Answer – CDRL B008 is deleted in its entirety.

Question - Page 36 of 51 – CDRL B009 – York assumes that this CDRL will be removed from the contract requirements.

Answer – CDRL B009 is deleted in its entirety.

Question - Page 38 of 51 – CDRL B010 – York assumes that this CDRL will be removed from the contract requirements.

Answer – CDRL B010 is deleted in its entirety.

Question - Page 39 of 51 – CDRL B011 – York assumes that this CDRL will be removed from the contract requirements.

Answer – CDRL B011 is deleted in its entirety.

Question - Page 40 of 51 – CDRL B012 – York assumes that this CDRL will be removed from the contract requirements.

Answer – CDRL B012 is deleted in its entirety.

Question - Page 42 of 51 – List of Government Furnished Information – Item 1 “300 Ton HFC-236fa Microprocessor Based Control Algorithm” is not required to provide the Auxiliary Equipment ordered by this solicitation.

Answer – The 300 Ton HFC-236fa Microprocessor Based Control Algorithm is deleted in its entirety.

Question - Page 43 of 51 – List of Government Furnished Information – Item 2, York assumes that the technical manual provided as government furnished information is NAVSEA S9514-C5-MMA-010 which is applicable to the 300 Ton HFC-236fa Centrifugal A/C Plants on board LHD-1 through LHD-7.

Answer – That’s correct.

2. CORRECTIONS TO THE SOLICITATION

Due to reorganization, any references to Code 9213 in the solicitation are changed to read Code 921.

Section C, Page 3, under Configuration Management reads as follows:

The Physical and Functional Configuration Baselines for the HFC-236fa in lieu of HGC-236fa.

Section F, Page 9, second paragraph under Shipping Address reads as follows:

If shipping instructions have not been provided within sixty (60) days prior to first scheduled delivery date, the Contractor shall submit a written request for shipping to the Naval Surface Warfare Center, Carderock Division, Attn: Code 921, 5001 South Broad Street, Philadelphia, PA 19112....Contract Administration Office.